



MICHAEL R.
DINGELSTEDT

Township of

Maplewood



CARL W. KLING JR.
DEPUTY CHIEF/EXECUTIVE

Fire Safety Permit requirements for outdoor cooking area

Approval is contingent upon adherence to the following conditions:

- 1) Canopy and stove must be those approved by Fire Official.
- 2) Certification of Flame Resistance must be provided for canopy.
- 3) Canopy must be separated from other tents/canopies by a minimum of 5 feet
- 4) LP-gas container shall be located a minimum of 5 feet from any heat-producing appliance and secured to prevent unauthorized movement.
- 5) LP-gas containers must be located outside or on the exterior perimeter of the canopy with safety release valve pointed away from the canopy.
- 6) At least one portable FIRE EXTINGUISHER with a minimum 2A:10BC rating shall be kept at the location where the flame producing device is in use.